

ADDENDUM 2

ST. MARTIN UPPER AND EAST ELEMENTARY SCHOOLS HVAC UPGRADES

Date: April 13, 2023

Project #: 0155.22.008

Project Name: ST. MARTIN UPPER AND EAST ELEMENTARY SCHOOLS HVAC UPGRADES
1100 Yellow Jacket Rd.
Ocean Springs, MS 39565

Owner: Jackson County School District
4700 Colonel Vickrey Road
Vancleave, Mississippi 39565

To: All Prospective Bidders

From: Micah van Duijvendijk, PE

Bidders are hereby informed that the Project Manual and Drawings are modified as follows:

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents with a submittal signed and stamped date of March 8, 2023. It is the General Contractor's responsibility for providing proper acknowledgement and receipt of this Addendum in the Bid Forms/Document.

Attachments to this Addendum: As described herein

Total Number of Pages in this Addendum: 2 Pages

PART A: GENERAL ADDENDUM, BIDDING, AND/OR PROJECT NOTES:

A1. None this addendum.

PART B: CONTRACTOR QUESTIONS WITH RESPONSES (Responses are in RED)

Note: If you do not see your question answered, then we are still researching or working on a solution.

B1. I do not see a specification section for the natural gas piping in the contract documents. Per IFGC 2018 section 403.3.9.5 threaded fittings are acceptable less than 4", and 402.7 note 1 states that welding is required when operating pressure exceeds 5 PSI. Finally, the connection of the Raypak boiler is a threaded connection. Please confirm the gas piping can be threaded in accordance with the IFGC and Unit connection method. **Confirmed. Threaded fittings are acceptable.**

PART C: DRAWING CLARIFICATIONS, REVISIONS, AND ADDITIONS:

C1. None this addendum.

Addendum 2
0155.22.008 ST. MARTIN UPPER AND EAST ELEMENTARY SCHOOLS HVAC UPGRADES

PART D: SPECIFICATION CLARIFICATIONS, REVISIONS, AND ADDITIONS

D1. None this addendum.

PART E: APPROVED PRODUCT/VENDOR EQUALS

E1. None this addendum.

END OF ADDENDUM 2