

## **ADDENDUM 02**

### **SCOTT COUNTY SCHOOL DISTRICT HVAC UPGRADES**

Date: July 31, 2023

Project #: 0303.23.001

Project Name: Scott County School District HVAC Upgrades  
Sebastopol Attendance Center – 17194 Hwy 21 N., Sebastopol, MS 39359  
Lake Middle School – 1770 East Scott Rd., Lake, MS 39092  
Lake High School – 24442 Hwy 80, Lake, MS 39092

Owner: Scott County School District  
110 Commerce Loop  
Forest, MS 39074

To: All Prospective Bidders

From: Bradford A. Jones, AIA

---

#### **Bidders are hereby informed that the Project Manual and Drawings are modified as follows:**

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents with a submittal signed and stamped date of June 16, 2023. It is the General Contractor's responsibility for providing proper acknowledgement and receipt of this Addendum in the Bid Forms/Document.

Attachments to this Addendum: As described herein

Total Number of Pages in this Addendum: 2 Pages

#### **PART A: GENERAL ADDENDUM, BIDDING, AND/OR PROJECT NOTES:**

A1. None this addendum

#### **PART B: CONTRACTOR QUESTIONS WITH RESPONSES (Responses are in RED)**

*Note: If you do not see your question answered, then we are still researching or working on a solution.*

B1. None this addendum

#### **PART C: DRAWING CLARIFICATIONS, REVISIONS, AND ADDITIONS:**

C1. None this addendum.

#### **PART D: SPECIFICATION CLARIFICATIONS, REVISIONS, AND ADDITIONS**

D1. None this addendum.

Addendum 02  
0303.23.001 Scott County School District HVAC Upgrades

**PART E: APPROVED PRODUCT/VENDOR EQUALS**

- E1. Lennox is an acceptable manufacturer for the HVAC equipment. All equipment shall meet listed capacities shown on drawings. Contractor is responsible for ensuring equipment fits and clearances can be met prior to bidding. All DOAS equipment shall be capable of simultaneous cooling and refrigerant reheat for active dehumidification.

**END OF ADDENDUM 02**