

## ADDENDUM 3 HVAC REPLACEMENT - GULFPORT SCHOOL DISTRICT

Date: Thursday, November 9, 2023

Project #: 0247.23.001

Project Name: HVAC Replacement - Gulfport School District

Owner: Gulfport School District  
2001 Pass Road  
Gulfport, Mississippi 39501

To: All Prospective Bidders

From: Tyler Abell, EI

---

### Bidders are hereby informed that the Project Manual and Drawings are modified as follows:

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents with a submittal date of Friday, October 13, 2023. It is the General Contractor's responsibility for providing proper acknowledgement and receipt of this Addendum in the Bid Forms/Document.

Attachments to this Addendum: As described herein

Total Number of Pages in this Addendum: 2 Pages

### PART A: GENERAL ADDENDUM, BIDDING, AND/OR PROJECT NOTES:

A1. None at this addendum.

### PART B: CONTRACTOR QUESTIONS WITH RESPONSES (Responses are in RED)

*Note: If you do not see your question answered, then we are still researching or working on a solution.*

- B1. Is the intent for Base Bid to be all (7) campuses, and then the (4) Alternates campuses would be Deducts? **Contractor shall select additive or deductive on bid form for alternates.**
- B2. What is contractor's warranty period? **1 year from date of substantial completion.**
- B3. How many sets of MERV 13 filters are we to provide per unit? **Contractor shall provide temporary filters during construction and ensure new set of MERV 13 filters are installed at substantial completion.**
- B4. If existing RTUs are already on adapter curbs, is it permissible to double stack adapter curbs? **Double stacked adapter curbs are not acceptable.**

### PART C: SPECIFICATION CLARIFICATIONS, REVISIONS, AND ADDITIONS:

C1. None at this addendum.

### PART D: DRAWING CLARIFICATIONS, REVISIONS, AND ADDITIONS:

Addendum #03  
0247.23.001 – HVAC Replacement

Page 1 of 2

D1. None at this addendum.

**PART E: APPROVED PRODUCT/VENDOR EQUALS**

E1. None at this addendum.

**END OF ADDENDUM 3**