

## ADDENDUM 6 HVAC REPLACEMENT - GULFPORT SCHOOL DISTRICT

Date: Wednesday, November 15, 2023

Project #: 0247.23.001

Project Name: HVAC Replacement - Gulfport School District

Owner: Gulfport School District  
2001 Pass Road  
Gulfport, Mississippi 39501

To: All Prospective Bidders

From: Tyler Abell, EI

---

### Bidders are hereby informed that the Project Manual and Drawings are modified as follows:

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents with a submittal date of Friday, October 13, 2023. It is the General Contractor's responsibility for providing proper acknowledgement and receipt of this Addendum in the Bid Forms/Document.

Attachments to this Addendum: As described herein

Total Number of Pages in this Addendum: 2 Pages

#### PART A: GENERAL ADDENDUM, BIDDING, AND/OR PROJECT NOTES:

- A1. None at this addendum.
- A2. Is single wall construction acceptable on Package units? **Single wall is acceptable.**
- A3. Clarify warranty requirements? **1-year parts and 5 year compressor.**

#### PART B: CONTRACTOR QUESTIONS WITH RESPONSES (Responses are in RED)

*Note: If you do not see your question answered, then we are still researching or working on a solution.*

- B1. None at this addendum.

#### PART C: SPECIFICATION CLARIFICATIONS, REVISIONS, AND ADDITIONS:

- C1. None at this addendum.

#### PART D: DRAWING CLARIFICATIONS, REVISIONS, AND ADDITIONS:

- D1. None at this addendum.

#### PART E: APPROVED PRODUCT/VENDOR EQUALS

Addendum #05  
0247.23.001 – HVAC Replacement

E1. None at this addendum.

**END OF ADDENDUM 6**