

ADDENDUM 04 SCOTT COUNTY SCHOOL DISTRICT HVAC UPGRADES

Date: August 10, 2023

Project #: 0303.23.001

Project Name: Scott County School District HVAC Upgrades
Sebastopol Attendance Center – 17194 Hwy 21 N., Sebastopol, MS 39359
Lake Middle School – 1770 East Scott Rd., Lake, MS 39092
Lake High School – 24442 Hwy 80, Lake, MS 39092

Owner: Scott County School District
110 Commerce Loop
Forest, MS 39074

To: All Prospective Bidders

From: Bradford A. Jones, AIA

Bidders are hereby informed that the Project Manual and Drawings are modified as follows:

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents with a submittal signed and stamped date of June 16, 2023. It is the General Contractor's responsibility for providing proper acknowledgement and receipt of this Addendum in the Bid Forms/Document.

Attachments to this Addendum: As described herein

Total Number of Pages in this Addendum: 2 Pages

PART A: GENERAL ADDENDUM, BIDDING, AND/OR PROJECT NOTES:

A1. None this addendum.

PART B: CONTRACTOR QUESTIONS WITH RESPONSES (Responses are in RED)

Note: If you do not see your question answered, then we are still researching or working on a solution.

B1. None this addendum

PART C: DRAWING CLARIFICATIONS, REVISIONS, AND ADDITIONS:

C1. Grille schedule added to M601. Replace sheet M601 in its entirety.

PART D: SPECIFICATION CLARIFICATIONS, REVISIONS, AND ADDITIONS

D1. None this addendum.

Addendum 04
0303.23.001 Scott County School District HVAC Upgrades

PART E: APPROVED PRODUCT/VENDOR EQUALS

- E1. 5:1 turndown on chiller is acceptable in lieu of hot gas bypass.
- E2. Trane is an acceptable manufacturer of equipment. Equipment must meet same capacity as specified units. DOAS units shall meet requirements of specified units and must have refrigerant reheat for dehumidification.
- E3. Renewaire is an acceptable manufacturer for equipment. Equipment must meet same capacity as specified units.

END OF ADDENDUM 04